

Am Test Inc.  
 13600 NE 126TH PL  
 Suite C  
 Kirkland, WA 98034  
 (425) 885-1664



Professional  
 Analytical  
 Services

## Haloacetic Acid (HAA5)

### Distribution System - Report of Analysis

<b>HALOACETIC ACIDS</b>	System Group Type: <input checked="" type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other:
Water System ID Number: 28300Y	System Name: CITY OF GOLD BAR
Source: S92 (Distribution samples)	County: SNOHOMISH
Sample Purpose: (Check Appropriate Box) <input checked="" type="checkbox"/> Routine/Compliance (satisfies monitoring requirements) <input type="checkbox"/> Confirmation (confirmation of chemical result) <input type="checkbox"/> Investigative (does not satisfy monitoring requirements) <input type="checkbox"/> Other (specify)	Date Received: 07/15/22 Date Analyzed: 7/20/22 Date Reported: 8/ 4/22 Comments:
Sample Composition: (Check Appropriate Box) <input type="checkbox"/> Single Source <input type="checkbox"/> Blended (List Multiple Source Numbers in Source Nos. field) <input type="checkbox"/> Composite (Specify in Comments Field) <input checked="" type="checkbox"/> Distribution Sample	Sample Type: (Check One) <input type="checkbox"/> Pre-Treatment/Raw <input checked="" type="checkbox"/> Post-Treatment/Finished <input type="checkbox"/> Unknown Sample Collected by: RICHARD BAKER Phone Number: 425-238-1935
Send Report To: CITY OF GOLD BAR 107 5TH ST. GOLD BAR, WA 98251	Bill To: RICHARD BAKER 107 5TH ST. GOLD BAR, WA 98251

**Analyte Abbreviations:**

Monochloroacetic Acid = "MCAA"    Dichloroacetic Acid = "DCAA"    Trichloroacetic Acid = "TCAA"    Monobromoacetic Acid = "MBAA"    Dibromoacetic Acid = "DBAA"    Total Haloacetic Acids = "HAA5's"

Analytical Method / Analyst Initials: EPA 552.2 / NNL

(DOH#) ANALYTE	(0411) MCAA (ug/L)	(0412) DCAA (ug/L)	(0413) TCAA (ug/L)	(0414) MBAA (ug/L)	(0415) DBAA (ug/L)	(0416) HAA5's (ug/L)
SDRL	2.0	1.0	1.0	1.0	1.0	6.0
MCL	--	--	--	--	--	60**

**HAA5 RESULTS**

Lab Number / Sample Number	Date Collected	Location Where Sample Collected	MCAA (ug/L)	DCAA (ug/L)	TCAA (ug/L)	MBAA (ug/L)	DBAA (ug/L)	HAA5's (ug/L)
066 / 11933	07/15/2022	715 CROFT AVE W.	<2	1.21	1.45	<1	2.28	4.9