

Am Test Inc.
 13600 NE 126TH PL
 Suite C
 Kirkland, WA 98034
 (425) 885-1664
 www.amtestlab.com



**Professional
 Analytical
 Services**

Select Inorganic Chemistry Report of Analysis

Date Collected: 03/07/24	System Group Type: <input checked="" type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> Other:
Water System ID Number: 28300Y	System Name: City of Gold Bar
Lab--Sample No: 066--04929	County: Snohomish
Sample Location: TANK ROAD	Source Number(s): S03 & S04
Sample Purpose: (Check Appropriate Box) <input checked="" type="checkbox"/> RC - Routine/Compliance (satisfies monitoring requirements) <input type="checkbox"/> C - Confirmation (confirmation of chemical result) <input type="checkbox"/> I - Investigative (does not satisfy monitoring requirements) <input type="checkbox"/> O - Other (specify)	Date Received: 3/7/24 Date Reported: 5/15/24 Comments:
Sample Composition: (Check Appropriate Box) <input type="checkbox"/> S - Single Source <input checked="" type="checkbox"/> B - Blended (List Multiple Source Numbers in Source Nos. field) <input type="checkbox"/> C - Composite (Specify in Comments Field) <input type="checkbox"/> D - Distribution Sample	Sample Type: (Check One) <input type="checkbox"/> Pre-Treatment/Raw <input checked="" type="checkbox"/> Post-Treatment/Finished <input type="checkbox"/> Unknown Sample Collected by: RICHARD BAKER Phone Number: 425-238-1935
Send Report To: City of Gold Bar Attention: Richard Baker 107 5th Street Gold Bar, WA 98251	Bill To: Richard Baker 107 5th Street Gold Bar, WA 98251

ANALYTICAL RESULTS

DOH#	ANALYTE	DATA QUALIFIER	RESULTS	SDRL	TRIGGER	MCL	UNITS	EXCEEDS MCL (X if Yes)	DATE ANALYZED	METHOD /INITIALS
0004	Arsenic		0.0046	0.0014	0.01	0.01	mg/l		3/19/24	EPA 200.8 /CM

NOTES:
***Confirmation:** Include the original lab number, sample number, and collection date of original sample in either comment section.
 - No existing trigger or MCL.
ANALYTE: The name of the analyte being tested for.
DATA QUALIFIER A symbol or letter to denote additional information about the result.
DOH#: Department assigned analyte number.
EXCEEDS MCL (Maximum Contaminant Level): Marked if the contaminant amount exceeds the MCL under chapters 246-290 and 246-291 WAC. Please contact the department's drinking water regional office in your area to determine follow-up actions.
METHOD/INITIALS: Analytical method used. /Initials of the analyst that performed the analysis.
mg/L: milligrams per liter or parts per million.
NTU: milligrams per liter or parts per million.
RESULT: The laboratory reported result.
SDRL (State Detection Reporting Level): The minimum reportable detection of an analyte as established by the department.
TRIGGER: The department's drinking water response level. Systems with contaminations detected at concentrations in excess of this level may be required to take additional samples or monitor more frequently. Please contact the department's drinking water regional office in your area for further information.
ND (Not Detected): In the results column indicates this compound was analyzed and not detected at a level greater than or equal to the SDRL.


 Seth Farb
 AmTest Inc.