

**Complete Inorganic Chemistry
ANALYSIS REPORT**

Date Collected: 10/02/25	System Group Type: ☒ A B Other:
Water System ID Number: 28300Y	System Name: City of Gold Bar
Lab Number/Sample Number: 0125-A25J0097-01	County: Snohomish
Sample Location: 40501 US-2	Source Number (s): S04
Sample Purpose: (Check Appropriate Box) ☒ RC - Routine Compliance (Satisfies monitoring requirements) C - Confirmation (Confirmation of chemical result) I - Investigative (Does not satisfy monitoring requirements) O - Other (Specify- does not satisfy monitoring requirements)	Date Received: 10/03/25 Date Reported: 10/21/25 Comments:
Sample Composition: (Check Appropriate Box) ☒ S - Single Source B - Blended (List source numbers in "Source Numbers" field) C - Composite (List source numbers in "Source Numbers" field) D - Distribution Sample	Sample Type: (Check One) Pre-treatment/Untreated (Raw) ☒ Post-treatment (Finished) Unknown or Other Sample Collected by: Richard Baker Phone Number: 360-793-1101
Send Report To: City of Gold Bar 107 5th Street, Gold Bar, WA 98251	Bill To: Richard Baker

ANALYTICAL RESULTS

DOH#	CONTAMINANT	DATA QUALIFIER	RESULT	SDRL	TRIGGER	MCL	UNITS	EXCEEDS MCL (X if Yes)	DATE ANALYZED	METHOD/ INITIALS
	11CI-PF3OUdS		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	1H,1H,2H,2H-Perfluorodecane Sulfonic Acid (6.2FTS)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	1H,1H,2H,2H-Perfluorodecane Sulfonic Acid (8.2FTS)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	1H,1H,2H,2H-Perfluorooctane Sulfonic Acid (4.2FTS)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	4,8-Dioxa-3H-Perfluorononanoic Acid (ADONA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	9CI-PF3ONS		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Nonfluoro-3,6-Dioxaheptanoic Acid (NFDHA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoro(2-Ethoxyethane)sulfonic Acid (PFEEA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoro-3-Methoxypropionic Acid (PFMPA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoro-4-Methoxybutanoic Acid (PFMBA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorobutanesulfonic Acid (PFBS)		ND	2	345	NA	ng/L		10/15/25	EPA 533/ AL

ANALYTICAL RESULTS (Continued)

DOH#	CONTAMINANT	DATA QUALIFIER	RESULT	SDRL	TRIGGER	MCL	UNITS	EXCEEDS MCL (X if Yes)	DATE ANALYZED	METHOD/ INITIALS
	Perfluorobutanoic Acid (PFBA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorodecanoic Acid (PFDA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorododecanoic Acid (PFDoA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoroheptanesulfonic Acid (PFHpS)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoroheptanoic Acid (PFHpA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorohexanesulfonic Acid (PFHxS)		ND	2	65	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorohexanoic Acid (PFHxA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorononanoic Acid (PFNA)		ND	2	9	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorooctanesulfonic Acid (PFOS)		ND	2	15	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluorooctanoic Acid (PFOA)		ND	2	10	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoropentanesulfonic Acid (PFPeS)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoropentanoic Acid (PFPeA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL
	Perfluoroundecanoic Acid (PFUnA)		ND	2	NA	NA	ng/L		10/15/25	EPA 533/ AL

NOTES

***Confirmation:** Include the original lab number, sample number, and collection date of original sample in either comment section.

ND: Analyte not detected at or above the SDRL.

NA -No trigger value for combined nitrate plus nitrite.

1 Secondary MCL (Established for aesthetic purposes, not health based)

2 TDS is required to be run if conductivity exceeds the MCL.

DATA QUALIFIER A symbol or letter to denote additional information about the result.

DOH#: Department assigned analyte number.

EXCEEDS MCL (Maximum Contaminant Level): Marked if the contaminant amount exceeds the MCL under chapters 246-290 and 246-291 WAC.

Please contact the department's drinking water regional office in your area to determine follow-up actions.

mg/L: milligrams per liter or parts per million.

NTU: Nephelometric turbidity units.

RESULT: The laboratory reported result.

SDRL (State Detection Reporting Level): The minimum reportable detection of an analyte as established by the department.

TRIGGER: The department's drinking water response level. Systems with contaminations detected at concentrations in excess of this level may be required to take additional samples or monitor more frequently.



Seth Farb
Vice President

13600 NE 126th Pl., Suite C
Kirkland, WA 98034
425-885-1664

AMTEST

LABORATORIES

DRINKING WATER SAMPLE
INFORMATION (WSI)
For Chemical Analysis

Report To: <u>City of Gold Bar</u>	Bill To: <u>Same</u>
Address: <u>107 5th Street</u>	Address:
City: <u>Gold Bar</u> State: <u>WA</u> Zip: <u>98251</u>	City: State: Zip:
Phone: <u>360-793-1101</u>	SEND REPORT BY:
Email: <u>R. Baker @ City of Gold Bar, US</u>	☐ MAIL ☐ WEB ☒ EMAIL


Sampling Information REQUIRED	
1. ☐ Investigative ☒ Compliance – for State regulations for Public Water Systems. (Results will be sent to you and the State.)	
2. Date Collected: <u>10/2/2025</u>	Time Collected: <u>310</u> AM ☐ PM ☒
3. Collected By: <u>Richard Baker</u>	Telephone: <u>425-238-1935</u>
4. Specific Location where sample was taken: <u>40501 US-2</u>	

Water System Information REQUIRED	
5. System Name: <u>City of Gold Bar</u>	System ID #: <u>28300Y</u>
6. DOH Source #: <u>S04</u>	☐ Check here if this is a New Source
(Without a source number DOH will not accept samples. If sample is blended from more than one source, list all)	
7. Group: ☒ A ☐ B	8. County: <u>Snohomish</u>
9. Source Type: ☐ Surface ☐ Well/Ground Water ☒ Well Field ☐ Spring ☐ Purchased	
10. Sample Taken: ☐ Before Treatment ☒ After Treatment ☐ No Treatment ☐ In Distribution	
11. Treatment Type: ☐ None ☐ Aeration ☐ Filtration ☒ Chlorination ☐ Softener ☐ Other:	

Analysis to Perform (FREQUENTLY REQUESTED TESTS). FOR OTHERS, PLEASE LIST UNDER OTHER ANALYSIS					
Organic Compounds		Inorganic Compounds		OTHER ANALYSIS, Please List:	
☐ 524.2 - VOC		☐ Complete Inorganics (IOC)		<u>PFAS</u>	
☐ 552.2 - Haloacetic Acids (HAA)		☐ Plumbing			
☐ 524.2 - Trihalomethanes (THM)		☐ Arsenic			
Synthetic Organic Compounds (SOC)		☐ Nitrates in Drinking Water			
☐ 515 - Herbicides		☐ Snohomish County List			
☐ 525 - Insecticides/Pesticides		☐ 531 - Carbamates			
Relinquished By	Date	Time	Received By	Date	Time
<u>[Signature]</u>	<u>10/03/2025</u>	<u>9:55A.</u>	<u>[Signature]</u>	<u>10/3/25</u>	<u>956</u>

FOR LABORATORY USE ONLY				YES	NO	N/A
SAMPLE TEMP. <u>7.4</u> °C SATISFACTORY				☐	☐	☐
CHAIN OF CUSTODY & LABELS AGREE				☐	☐	☐
LABORATORY ID#		REQUESTED TAT:		PAYMENT:		
A25J0097-01		☐ NORM ☐ 2-DAY				
		☐ 5-DAY ☐ 24-HOURS				

Helpful Hints to fill out form on reverse



ANATEK LABS

Analytical Results Report For:

City of Gold Bar

Project Number:

A25J0097

Anatek Work Order:

MFJ0177

Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

Client: City of Gold Bar
Address: 13600 NE 126th Pl, STE C
Kirkland, WA 98034
Attn: Seth Farb

Work Order: MFJ0177
Project: A25J0097
Reported: 10/21/2025 10:24

Analytical Results Report

System ID# 28300Y System Name: City of Gold Bar
Reference Number: MFJ0177-01 Collect Date: 10/02/25 15:10 DOH Source #: 04
Multiple Source Nos: Sample Type: After County: Snohomish
Date Received: 10/07/25 09:36 Sample Purpose: RC - Routine/Compliance Sample
Sample Location: A25J0097-01
Matrix: Drinking Water

Lab/Sample Number: 125-17701

Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2.0	10		10/15/25 13:53	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2.0	15		10/15/25 13:53	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2.0	65		10/15/25 13:53	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2.0	9		10/15/25 13:53	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2.0	345		10/15/25 13:53	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0445	ADONA 4,8-Dioxo-3H-perfluorononanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0446	9CI-PF3ONS	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0448	11CI-PF3OUdS	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	

Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

Client: City of Gold Bar
Address: 13600 NE 126th Pl, STE C
Kirkland, WA 98034
Attn: Seth Farb

Work Order: MFJ0177
Project: A25J0097
Reported: 10/21/2025 10:24

Analytical Results Report

System ID# 28300Y System Name: City of Gold Bar
Reference Number: MFJ0177-01 Collect Date: 10/02/25 15:10 DOH Source #: 04
Multiple Source Nos: Sample Type: After County: Snohomish
Date Received: 10/07/25 09:36 Sample Purpose: RC - Routine/Compliance Sample
Sample Location: A25J0097-01
Matrix: Drinking Water

Lab/Sample Number: 125-17701

Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutan oic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropa noic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane) sulfonic acid	ND	ng/L	2.00	2.0	--		10/15/25 13:53	MER	EPA 533	

Authorized Signature,



Justin Doty For Todd Taruscio, Laboratory Manager

S12 Surrogate recovery was low.
LRL Lab Reporting Limit
SDRL State Detection Reporting Limit
ND Not Detected
MCL EPA's Maximum Contaminant Level
Dry Sample results reported on a dry weight basis
SAL State Action Level
* Not a certified analyte
RPD Relative Percent Difference
%REC Percent Recovery
Source Sample that was spiked or duplicated.

This report shall not be reproduced except in full, without the written approval of the laboratory
The results reported related only to the samples indicated.

Report To: <u>City of Gold Bae</u>	Bill To: <u>Same</u>
Address: <u>107 5th Street</u>	Address:
City: <u>Gold Bae</u> State: <u>WA</u> Zip: <u>98251</u>	City: State: Zip:
Phone: <u>360-793-1101</u>	SEND REPORT BY:
Email: <u>R. Baker @ City of Gold Bae, US</u>	☐ MAIL ☐ WEB ☒ EMAIL

Sampling Information REQUIRED

1. ☐ Investigative ☒ Compliance – for State regulations for Public Water Systems. (Results will be sent to you and the State.)
2. Date Collected: 10/2/2025 Time Collected: 310 AM ☐ PM ☒
3. Collected By: Richard Baker Telephone: 425-238-1935
4. Specific Location where sample was taken:
40501 US-2

Water System Information REQUIRED

5. System Name: City of Gold Bae System ID #: 28300Y
6. DOH Source #: S04 ☐ Check here if this is a New Source
(Without a source number DOH will not accept samples. If sample is blended from more than one source, list all)
7. Group: ☒ A ☐ B 8. County: Snohomish
9. Source Type: ☐ Surface ☐ Well/Ground Water ☒ Well Field ☐ Spring ☐ Purchased
10. Sample Taken: ☐ Before Treatment ☒ After Treatment ☐ No Treatment ☐ In Distribution
11. Treatment Type: ☐ None ☐ Aeration ☐ Filtration ☒ Chlorination ☐ Softener ☐ Other:

Analysis to Perform (FREQUENTLY REQUESTED TESTS): FOR OTHERS, PLEASE LIST UNDER OTHER ANALYSIS

Organic Compounds ☐ 524.2 - VOC ☐ 552.2 - Haloacetic Acids (HAA) ☐ 524.2 - Trihalomethanes (THM)	Inorganic Compounds ☐ Complete Inorganics (IOC) ☐ Plumbing ☐ Arsenic ☐ Nitrates in Drinking Water ☐ Snohomish County List	OTHER ANALYSIS, Please List: <u>PFAS</u>
Synthetic Organic Compounds (SOC) ☐ 515 - Herbicides ☐ 525 - Insecticides/Pesticides	☐ 531 - Carbamates	

Relinquished By	Date	Time	Received By	Date	Time
<u>[Signature]</u>	<u>10/03/2025</u>	<u>9:55A.</u>	<u>[Signature]</u>	<u>10/3/25</u>	<u>956</u>

FOR LABORATORY USE ONLY

SAMPLE TEMP. <u>7.4 °C</u> SATISFACTORY	YES	NO	N/A
CHAIN OF CUSTODY & LABELS AGREE	☐	☐	☐
LABORATORY ID# A25J0097-01	REQUESTED TAT: ☐ NORM ☐ 2-DAY ☐ 5-DAY ☐ 24-HOURS	PAYMENT:	

Helpful Hints to fill out form on reverse



Sample Receipt and Preservation Form

Cooler Temperature	
Read (°C):	0.1
Corrected (°C):	-
Thermometer Used:	
IR-4	IR-6

Client Name: AmTest: City of Gold Bar

TAT: Normal RUSH: _____ days

Samples Received From: FedEx UPS USPS Client Courier Other: _____

Custody Seal on Cooler/Box: Yes No Custody Seals Intact: Yes No N/A

Number of Coolers/Boxes: 3 Type of Ice: Wet Ice Ice Packs Dry Ice None

Packing Material: Bubble Wrap Bags Foam/Peanuts Paper None Other: _____

Samples Received Intact?	<u>Yes</u>	No	N/A
Chain of Custody Present/Complete?	<u>Yes</u>	No	N/A
Labels and Chains Agree?	<u>Yes</u>	No	N/A
Samples Received Within Hold Time?	<u>Yes</u>	No	N/A
Correct Containers Received?	<u>Yes</u>	No	N/A
Anatek Bottles Used?	<u>Yes</u>	No	Unknown

Total Number of Sample Bottles Received: 3

Samples Properly Preserved? Yes No N/A

If No, record preservation and pH-after details

VOC Vials Free of Headspace (<6mm)? Yes No N/A

VOC Trip Blanks Present? Yes No N/A

Comments:

Initial pH: <2 or	pH Paper ID:

Record preservatives (and lot numbers, if known) for containers below:

P250 NH4Ac (2415) 533 x 3

Notes, comments, etc. (also use this space if contacting the client - record names and date/time)

Received/Inspected By: JP Date/Time: 10/07/25 0934